



HANOVER COUNTY

Office of the Fire Marshal



Office (804) 365-6195
Fax (804) 537-5488

13326 Hanover Courthouse Road
P.O. Box 470 Hanover, VA 23069

fmo@hanovercounty.gov
Dispatch (804) 365-6140

Listed Below are the Requirements for Mobile Food Vendor
*** Indicates Required Action**

General Information	Yes	No	Comments
Current License Plate (TAG#)			
Current State Inspection Sticker (Valid)			
Current Vehicle Insurance			
*Health Department Inspection Form			
*Hanover County Fire Marshal Permit Sticker			
L P Gas Requirements	Yes	No	Comments
* LP Tanks Securely mounted			
*LP Tanks stored upright			
*LP Gas Alarm Installed and working as designed			
LP Tanks if enclosed properly vented and sealed			
LP Tanks –Does not exceed 200 gallons total			
Gas Lines verified that there are no leaks			
Cooking Oil Storage	Yes	No	Comments
Storage containers not exceeding 120 gallons			
Interior	Yes	No	Comments
No public seating allowed within the MFPV			
Appliances	Yes	No	Comments
*Appliances are secured to prevent movement			
Appliances installed are approved			
Gas Fired appliances equipped w/ shut off valves			
Exhaust Hoods	Yes	No	Comments
*Exhaust Hood Present (Type 1)			
*Exhaust Hood free of grease laden vapors			
*Hood cleaned as required (12 month max)			
Hood Inspected (Date in Comments)			
Copy of Hood Cleaning Inspection Report			
Filters in place			
Automatic Extinguishing System	Yes	No	Comments
*Automatic Extinguishing System Present			
*Automatic Extinguishing System Inspected			
Copy of Extinguishing System Inspection Report			
Extinguishers	Yes	No	Comments
ABC Extinguisher Present			
Minimum of 2A:10BC (Max:50' travel distance)			
Extinguisher Inspection Current			
Class K Extinguisher Present			
Class K Extinguisher Inspection Current			
Extinguishers are readily accessible			